



WHAT TO DO IN CASE OF ALARM

- 1) Press enter button once to silenced alarm if it is safe to do so
- 2) Check table below to determine cause of action

Alarm display	Action
AL1 triggered	Open doors and windows to ventilate area Look for the leak and remedy If alarm triggered again in 24hr period, contact service at _____
AL2 triggered	Immediately leave or do not enter the risk zone, leave exterior doors open for ventilation. Call CO2 service provider from outside the risk area. Call service at _____

- 3) After CO2 level go down to safe range, press enter button again to reset the alarm

Installer: complete these boxes before attaching this sign next to the central display
if one room has multiple alarm, put them at the same column

Sensor:	Location

